

# GENERATOR MAINTENANCE LOG

MAX HRS	SERVICE	DATE & HOURS					
Daily Service should be performed before every job on which the generator is to be in operation. Required repairs must be completed before the unit is returned to service.							
<b>DAILY</b>	Check Engine Oil Level – Add Oil						
<b>DAILY</b>	Check Coolant Level – Add Coolant						
<b>DAILY</b>	Check & Refill Fuel Tank						
<b>DAILY</b>	Check Fuel – Water Separator						
<b>DAILY</b>	Check Indicator Lights						
<b>DAILY</b>	Check Engine Speed						
<b>DAILY</b>	Overall Visual Inspection						
50	Check & Clean Radiator Fins						
50	Check Battery						
50	Drain Fuel – Water Separator						
250	Change Engine Oil & Filter						
Engine Oil & Filter to be changed after the first 50 hours of operation and every 250 hours thereafter.							
250	Clean Air Cleaner Element						
250	Drain Fuel Tank						
250	Check & Adjust Cooling Fan V-Belt						
Cooling fan V-Belt to be checked & adjusted after the first 50 hours of operation and every 250 hours thereafter.							
500	Replace Air Cleaner Element						
500	Clean Fuel – Water Separator						
500	Replace Fuel Filter						
1000	Drain Flush & Refill Coolant						
1000	Adjust Intake & Exhaust Valve Clearance						
1500	Inspect Clean & Test Fuel Injectors						
1500	Inspect Turbocharger						
1500	Inspect Clean & Test EGR Valve						
1500	Clean EGR Lead Valve						
1500	Clean EGR Cooler						
1500	Inspect Crankcase Breather System						
2000	Lap Intake & Exhaust Valve Seats						
2000	Replace Fuel & Cooling System Hoses						

**For more information on Generator maintenance procedures see your Yanmar TNV Operator's Manual or contact your authorized Yanmar industrial engine dealer or Pramac distributor**